

NFPA 70E Table 130.4(D)(a)

Shock Protection Boundaries to Exposed Energized Electrical Conductors or Circuit Parts for Alternating-Current Systems

Nominal System Voltage	Limited Approach Boundary	Restricted Approach Boundary
Less than 50 V	Not Specified	Not Specified
50 V to 150 V	3 feet, 6 inches	Avoid Contact
151 V to 750 V	3 feet, 6 inches	1 foot
751 V to 15 kV	5 feet	2 feet, 2 inches
<i>Over 15 kV or a movable conductor (a condition in which the distance between the conductor and a person is not under the control of the person)</i>		
<i>See NFPA 70 E Table 130.4 (D)(a)</i>		